














Engine No. 37196903	Displacement 30:1860	L: in3	Valve Lash Cold (mm: in)		Warranty Start Date:
Family D573001GX03	Static Injection Timing 17.5	° BTDC	Intake 0.43:0.017		
Model AS130-G4	Fuel Rate @ Advertised Power 420	mm3/stroke	Exhaust 0.80:0.032		
S.O. No. 10719	Assembled by Cummins Engine Co., Inc. U.S.A. 3093509		Advertised Power	KW-HP	RPM
Rel. No. 2632469	WARNING: Injury may result and warranty is voided if fuel rate, speed or altitude exceeds published maximum values for this model and application.		Standby	969:1300	at 1500 1111:190
CPL 1100			Prime	980:1180	at 1500 1007:1350
					at 1800

SERIAL NUMBER	0131367/01	NEWAGE NEWAGE INTERNATIONAL LTD. PO BOX 17, BARNACK ROAD STAMFORD, LINCOLNSHIRE PE9 2NB, ENGLAND MADE IN ENGLAND WEEK NO: 06/01 WARNING REFER TO THE INSTRUCTION BOOK BEFORE PLACING IN SERVICE TESTING BS 5000: PART 3 IEC 34-1 NEMA MG 1-32 ISO 8528-3 STAMFORD AC GENERATORS
MACHINE ID NUMBER	01062821	
FRAME/CORE	HC. I634K1	
KVA BASE RATE (BR)	1000	
KW BASE RATE (BR)	800	
HZ	50	
RPM	1500	
VOLTS	415	
PHASE	3	
AMPS BASE RATE (BR)	1391.24	
PF	0.8	
RATING	CONT	
EX. VOLTS	58	
EX. AMPS	3.30	
AMBIENT TEMP. C	40 C	
ENCLOSURE	IP22	
INSULATION CLASS	CLASS H	
STATOR WDG.	311	
STATOR CONN.	S. STAR	
AUR	PMG	

SERIAL NO: 0131367/01

MACHINE ID: 01062821

FRAME/CORE: HC.64K

WDG: 311

MADE IN ENGLAND

