











4101E



DANGER
THIS MACHINE IS
REMOTELY CONTROLLED
AND MAY START
WITHOUT WARNING

STOP
RUN AUTO
EMERGENCY STOP
TESTS
AUTO TEST2
GENERATOR AVAILABLE
GENERATOR ON LOAD
LAMP TEST
LAMP ON LOAD
LAMP AVAILABLE



GENERATOR
all subject is maintained by
FLORIDA
0800 5256000
service support 24 hours a day

LAMP TEST / RESET

- FAIL TO START
- HIGH ENGINE TEMPERATURE
- LOW OIL PRESSURE
- OVERHEATED / EMERGENCY STOP OPERATED
- LOW LOW FUEL LEVEL
- LOW BATTERY VOLTAGE
- NOT IN AUTO MODE
- APPROACHING HIGH ENGINE TEMPERATURE
- APPROACHING LOW OIL PRESSURE
- BATTERY CHARGER FAILURE

2-3-25 1000000
2-3-25 1000000
2-3-25 1000000



ABB
1 on
0 off
100A

1188269 h

GEN ⚡ PART

F G Wilson (Engineering) Ltd
 Old Glenarm Road
 Larne, Co. Antrim BT40 1EJ
 Northern Ireland, United Kingdom
 Tel: +44 (0) 28 2826 1000
 Fax: +44 (0) 28 2826 1111
 www.FGWilson.com



GENERATING SET

MODEL	P380	
SERIAL NUMBER	FGWPES01AM0A09733	
YEAR OF MANUFACTURE	2001	
RATED POWER - CONTINUOUS	380	kVA
	304	kW
	0.8	COS Ø
RATED VOLTAGE	415 / 240	V
PHASE	3	
RATED FREQUENCY	50	Hz
RATED CURRENT	528.7	A
RATED R.P.M	1500	
MAXIMUM ALTITUDE *	152.4	m
MAXIMUM AMBIENT		
TEMPERATURE *	27	°C
MASS	6616	Kg
SALES ORDER REFERENCE	48201/0020	

ALTERNATOR CONNECTION	S-STAR
RATING ISO 8528-3	BR
ALTERNATOR ENCLOSURE	IP22
INSULATION CLASS	H
EXCITATION VOLTAGE	34
EXCITATION CURRENT	3
A.V.R	
MADE IN UK	R448C

*GENERATOR SET IS DESIGNED TO OPERATE IN AMBIENT TEMPERATURES UP TO 50°C
 AND AT HIGHER ALTITUDES. PLEASE CONSULT FACTORY FOR OUTPUTS AVAILABLE

Perkins Engines (Shrewsbury) Ltd
Shrewsbury England



For spares quote Engine No. and
CFL Number

Engine number

SGJ06 0647 U3565H

Customer Part No.

101-303BL

Designation

2006TTAG

CFL Number

Valve clearance cold In.

• 010 IN • 25MM

Valve clearance cold Exh.

• 020 IN • 50MM

Injection timing

14°

BTDC